

11-Item Water Quality Test

No.	Test Item	Standard Value
1	General Bacteria	Colony count per 1 mL of sample water: Not more than 100
2	E. coli	Not Detected
3	Nitrite Nitrogen	Not more than 0.04 mg/L
4	Nitrate Nitrogen and Nitrite Nitrogen	Not more than 10 mg/L
5	Chloride Ion	Not more than 200 mg/L
6	Organic Matter [Total Organic Carbon (TOC)]	Not more than 3 mg/L
7	pH	5.8-8.6
8	Taste	No abnormality detected
9	Odor	No abnormality detected
10	Color	Not more than 5 units
11	Turbidity	Not more than 2 units

