

7-Item Organic Chemical Substances Test

No.	Test Item	Standard Value
1	Carbon Tetrachloride	Not more than 0.002 mg/L
2	cis-1,2-Dichloroethylene and trans-1,2-Dichloroethylene	Not more than 0.04 mg/L
3	Dichloromethane	Not more than 0.02 mg/L
4	Tetrachloroethylene	Not more than 0.01 mg/L
5	Trichloroethylene	Not more than 0.01 mg/L
6	Benzene	Not more than 0.01 mg/L
7	Phenols	Not more than 0.005 mg/L (as phenol equivalent)