

## 6-Item Pool Water Test

No.	Test Item	Standard Value
1	pH	pH 5.8-8.6
2	Turbidity	Not more than 2 units
3	Potassium Permanganate Consumption	Not more than 12 mg/L
4	E. coli	Not Detected
5	General Bacteria	Colony count per 1 mL of sample water: Not more than 200 CFU
6	Free Residual Chlorine Concentration	Not less than 0.4 mg/L; preferably not more than 1.0 mg/L; when disinfecting with chlorine dioxide: not less than 0.1 mg/L and not more than 0.4 mg/L. Chlorite concentration must not exceed 1.2 mg/L.

